



South Coast Air Quality Management District

21865 Copley Drive, Diamond Bar, CA 91765-4178
(909) 396-2000 • www.aqmd.gov

April 6, 2006

Mr. Gerardo Rios via e-mail
Chief, Permits Office
U.S. EPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105-3901

SUBJECT: Request for Expedited Review
Mountainview Power Company LLC – Emergency IC Engine Change of Condition
Facility ID # 121737, Facility Location: 2492 W San Bernardino Ave., Redlands, CA 92374-5016

Dear Mr. Rios:


The South Coast Air Quality Management District (AQMD) has received and reviewed permit applications for the subject facility. The Mountainview Power Company LLC is proposing to change an existing permit condition that would allow the use of an automatic fuel injection timing retard instead of mechanical adjustment to a fixed timing retard as required by the permit condition on a new 2,155 Hp emergency IC engine. No increase in pollutant emissions is expected as a result of this change of condition.

The AQMD has evaluated the subject permit applications and made a preliminary determination that the equipment will comply with all of the applicable requirements of our rules and regulations. Pursuant to Rule 3000(b)(12), the proposed change of condition is considered a Minor Permit Revision to the Title V permit since among other requirements, does not result in an emission increase of a pollutant subject to New Source Review or a HAP. Under Rule 3003(k)(1), EPA is afforded a 45-day review period from receipt of the application. The AQMD intends to issue a revision to the Facility Permit upon EPA approval.

Please find attached a copy of AQMD's engineering analysis for the proposed change of condition along with a copy of the draft Section H of the proposed Facility Permit.

If you wish to provide comments or have any questions regarding these proposed changes, please contact Mr. Emmanuel Ruivivar at (909) 396-2509/ eruivivar@aqmd.gov.

Sincerely,

for 

Pang Mueller
Senior Manager
Refinery, Energy & RECLAIM Administration
Engineering and Compliance

Attachments
CM:TV:JTY:ERR

cc: USEPA Region IX, via e-mail, "R9AirPermits_SC@epa.gov"
Russell Koelsch, Mountainview Power w/ attachments
Energy Unit files